


8.0 Test Summary			
Evaluation Period	8/13/2008		Project No. 3157187
Sample Rec. Date	8/13/2008	Condition Prototype	Sample ID. 001-008
Test Location	Richardson, Texas		
Test Procedure	Testing Lab		
Determination of the result includes consideration of measurement uncertainty from the test equipment and methods. The product was tested as indicated below with results in conformance to the relevant test criteria.			
The following tests were performed:			
Test Description	UL 1449 Third Edition, Dated September 29, 2006		
Dielectric Voltage-Withstand Test	35		
Surge Testing	37		
Operational Voltage Test	38		
Limited current abnormal overvoltage test	39.4		
Grounding Continuity Test	40		
Evaluation Period	8/13/2008		Project No. 3157187
Sample Rec. Date	8/13/2008	Condition Prototype	Sample ID. 453A-453E
Test Location	Bussmann Cooper/Bussmann		
Test Procedure	Testing Lab		
Determination of the result includes consideration of measurement uncertainty from the test equipment and			
The following tests were performed:			
Test Description	UL 1449 Third Edition, Dated September 29, 2006		
Short circuit current rating test – For Type 1 and Type 2 SPDs	39.2		
Intermediate current test	39.3		
Evaluation Period	3/9/2012		Project No. G100675161
Sample Rec. Date	NA	Condition Prototype	Sample ID. NA
Test Location	Intertek Testing Services NA, Inc 1809 10th Street, Suite #400, Plano, TX 75074		
Test Procedure	Testing Lab		
No additional testing was required for the standard update			
8.1 Signatures			
A representative sample of the product covered by this report has been evaluated and found to comply with the applicable requirements of the standards indicated in Section 1.0.			
Completed by:	Rashmi Doddaveeregowda	Reviewed by:	Javier Lozano
Title:	Compliance Investigator	Title:	Senior Compliance Investigator
Signature:		Signature:	